



FIRE UNDERWRITERS SURVEY

A SERVICE TO INSURERS AND MUNICIPALITIES

c/o CGI Information Systems and Management Consultants Inc., 90 Allstate Parkway, Markham, Ontario L3R 6H3
Telephone: (905) 474-0003 • Toll-free: 1-800-268-8080 • Fax: (905) 474-5604

December 15, 2006

Fire Chief Randy Smith
Township of Tiny
130 Balm Beach Rd., R. R. # 1
Perkinsfield, Ontario
L0L 2J0

Subject: **Superior Tanker Shuttle Accreditation**

Dear Chief Smith:

The Fire Underwriters' Survey is pleased to give your municipality Superior Tanker Shuttle Accreditation. The test procedure was carried out on November 18, 2006 with the undersigned present. The flow rate during the 2-hour test period averaged 2,315 litres per minute or 510 imperial gallons per minute.

Your team worked in a well co-ordinated and organized manner with proper supervision.

Regards,

Peter J. Rose, C.E.T., F.P.T.
Fire Protection Specialist